Modular cavity status and test plan

Daniel Bowring

Fermi National Accelerator Facility

May 30, 2014




Modular cavity status and test plan

Daniel Bowrie

Overview


RF Measurements

Experimental Pl



- 1. Frequency and *Q* have been verified.
- The cavity has not been delivered to FNAL yet.
 Endplate flanges are mechanically weak, making the RF joint unstable.
- 3. We believe this is a solved problem.
- Meanwhile, what is the experimental plan? (Plus: photos.)

RF Measurements




Modular cavity tatus and test plan

Overview

RF Measurement

Experimental Plan

We have verified the RF properties of the cavity.




(Quantitative data on next slide.)


Experimental Plan


| ٠ | | | | | | | |
|---|---|---|---|---|---|---|---|
| J | v | e | n | 4 | e | W | 1 |
| | | | | | | | |


RF Measurement

Experimental Plan










RF Measurements

Experimental Plan Photos

- Full design analysis and recovery discussion took place yesterday evening: https://indico.fnal.gov/contributionDisplay. py?sessionId=16&contribId=133&confId=8326
- Minimally invasive plan gets the cavity to FNAL ASAP.
- Staged "upgrades" possible if the minimally invasive fix proves insufficient.

Experimental Plan



Modular cavity tatus and test plan

Overview


RF Measurements

Experimental Plan

Experimental goals of the modular cavity program

The modular cavity allows us to collect "clean" data.

- Mimics coupling strategy in a cooling channel.
- Strongest surface E-field (by 5×) is on-axis.



We can test different materials and surface treatments.

- Beryllium vs. copper
- Half-hard vs. fully-annealed Cu
- Chemical polishing vs. electropolishing
- ▶ Other materials?

Modular cavity status and test plan

Overview

RF Measurements

xperimental Plar

Sequence of runs

- Chemically-polished Cu plates, B=3/0
- Chemically-polished Cu plates, B=0/3
- Beryllium plates, B=TBD
- 4. Fully-annealed Cu plates
- 5. "Other" (15 cm body, Cu alloy plates, etc.)


What does a single run look like?

- i. Inspection
- ii. Conditioning
- iii. Inspection
- iv. Establish safe operating gradient
- v. Inspection

Notation: B=3/0 denotes a run at 3 T followed by a run at 0 T.

Frequent inspection help us understand when damage occurs.





Modular cavity status and test plan

Overview

RF Measurements

Experimental Plan

Photos




Modular cavity status and test plan

Daniel Barrei

Overview

RF Measurements

×perimental



Modular cavity tatus and test plan


Daniel Bowri

Overview

RF Measurements

Experimental Plan

'hotos




odular cavity atus and test plan

Daniel Bowr

Overview

RF Measurements

Experimental Plan



Modular cavity tatus and test

Daniel Rowri

)verview

RF Measurements

Experimental Plan

'hotos



fodular cavity tatus and test plan

Overview

RF Measurements

Experimental Plan



Modular cavity tatus and test

Daniel Bowr

)verview

RF Measurements

perimentari



Modular cavity tatus and test plan

RF Measurements